



THE MUNICIPALITY OF SOUTH BRUCE

**P.O. Box 540
21 Gordon Street E.
Teeswater, Ontario
N0G 2S0
Telephone No. (519) 392-6623**

REQUEST FOR Proposal 2019-04

SPECIFICATION

Supply, Delivery and Installation of one (1) Diesel 347/600V,100kw “Tier 3” Standby Generator and 200A Auto Transfer Switch at 126 Elora Street, Mildmay, Ontario N0G 2S0. Quotations are invited and will be received for the above by the Public Works until 12:00:00 Noon EST Wednesday April 24, 2019.

Name: _____

Address: _____

Postal Code: _____

Telephone: _____ Fax: _____

Contact Person: _____

A. GENERAL

- A.1 It is the intent of these specifications to describe a Diesel 347/600V,100kw Tier 3 Standby generator and Auto Transfer Switch in sufficient detail to secure bids on comparable equipment. This specification is a guide and bidders may quote on additional options if they consider it in the interest to the Municipality.
- A.2 Formal Quotations are to state a firm delivery date from the date the quotation is accepted.
- A.3 The quotation shall state the location of the nearest repair facility.
- A.4 The Bidder is to include a full specification sheet or brochure for their product.

- A.5 The successful bidder will be required to instruct Municipal staff on-site, in the safe operation and use of the equipment at no additional cost to the Municipality.
- A.6 The Municipality reserves the right, at its own discretion, to accept or reject any bid and that the lowest or any bid will not necessarily be accepted. The Bidder understands that fundamental to this competition is the selection of a quotation that in the sole judgment of the Municipality, most effectively meets the requirements of the Municipality.

B. QUOTATION ASSESSMENT & EVALUATION

In arriving at a decision on a successful quotation the following criteria and priorities shall be used to assess all quotations:

QUOTATION PRICE

DELIVERY DATE

CONFIRMATION WITH SPECIFICATIONS

CUSTOMER SERVICE EXPERIENCE

SERVICE AND REPAIR BACK UP

REPAIR FACILITY LOCATION

C. CLOSING OF QUOTATIONS

Formal quotations will be received up to **12:00:00 Noon EST Wednesday April 24, 2019**

Sealed quotations shall be clearly marked "Formal Quotation for Diesel 347/600V,100kw Standby Generator" in a sealed envelope and received by the Public Works Department, Attention: Gary Pipe. Faxed or emailed formal quotations will not be accepted.

Late quotations will not be considered.

For further information on the Formal Quotation please contact Gary Pipe, Operations Manager, Municipality of South Bruce 519-392-6623.

Specifications for Diesel 347/600V,100kw Tier 3 Standby Generator and Auto Transfer Switch as follows:

1. Generator Details

-
1. Diesel engine 347/600V,100kw @ 1800RPM Perkins "Tier 3"
-

Digital engine control, AC readings, engine parameter display, 100% rated main line breaker, engine heater, silencer with flex, sound attenuated enclosure, battery charger, starting battery & cables, full load tested.

CSA approved.

2 year/3000hr warranty

2. PMG Excitation system with 300% short circuit sustaining capability for large motor starting and superior non-linear load carrying capability.
 3. Double wall sub-base fuel tank TSSA approved to provide approximately 55 hours of run time at 50% load and connected to the diesel generator set above.
 4. Auto Transfer Switch 600v 3phase, Nema-1 for indoor use.
 5. Delivery of unit set on concrete pad, commissioning of unit and proper training
 6. Sewage Plant Grade Unit
-
-

BIDDER TO PROVIDE SPECIFICATIONS OR CLARIFY DIFFERENCES FROM SPECS INCLUDED ABOVE:

CLARIFICATION OR REASON FOR DIFFERENCES

THE COPORATION OF THE MUNICIPALITY OF SOUTH BRUCE

**REQUEST FOR FORMAL QUOTATION NO. 2019-04
 SUPPLY, DELIVERY AND INSTALATION OF A Diesel 120/208V Tier 3 Standby Generator
 and Auto Transfer Switch**

Product Acceptance:

The equipment that is supplied will meet or exceed the preceding specifications.

The equipment will include all parts or components not specifically mentioned, yet which are deemed standard and necessary to provide a complete unit, services and ready to work.

The equipment shall be new, current year, manufacture incorporating the manufacturers' latest design and production standards.

Upon delivery the equipment will be inspected for compliance to order description. Any deficiencies will be required to be corrected before payment is approved or an appropriate credit adjustment is agreed upon.

We understand from the above Specifications and agree to provide the equipment (exclusive of optional prices, extended warranties and trade in allowance) for the total sum of: _____

Generator must be delivered no later than July 31st 2019 to 126 Elora Street, Mildmay, Ontario

EXHIBIT	DESCRIPTION	BID PRICE
1	Supply, delivery and installation of a Diesel 347/600V, 100kw Tier 3 standby generator and 200A Auto Transfer Switch at 25 Otter Cres. Mildmay Ont.	\$
	13% HST	\$
	TOTAL	\$

Delivery Date of Product: _____

Location of Nearest Repair Facility: _____

AUTHORIZED OFFICIAL signing for BINDING contract:

Signature of OFFICIAL: _____ Title: _____

Dated at: _____